

SUBMITTAL DATA SHEET

Multi Zone Reguler Heat + Duct Series









| Location: | |
|---------------|--|
| Engineer: | |
| Submitted to: | |
| Submitted by: | |
| Reference: | |



| EFFICIENCY | | | |
|------------|------|---------|------|
| Coo | ling | Hea | ting |
| SEER2 | 20.4 | HSPF2-4 | 10.6 |
| EER2 | 12.0 | COP | 3.9 |

| PERFORMANCE of Cooling | | |
|--------------------------|--------------------------|--|
| Cooling (Btu/hr) | | |
| Rated Capacity 45000 | | |
| Min/Max Capacity | 12000~52000 | |
| Moisture Removal | 2.5 | |
| Standard Operating Range | -13°F~122°F (-25°C~50°C) | |

Rated Cooling Conditions: Indoor: 80°F DB/67°F WB
Outdoor: 95°F DB/75°F WB

| PERFORMANCE of Heating | | |
|-----------------------------------|--------------------------|--|
| Heating (Btu/hr) | | |
| 1. @ 47°F Rated (Min/Max) | 47000(13000~53000) | |
| 2. @ 17°F Rated | 37000 | |
| 3. @ 5°F Max: Capacity / COP | 38000/2.1 | |
| Standard Operating Range | -13°F~75°F (-25°C~24°C) | |
| 1. Rated Heating Conditions: | Indoor: 70°F DB/60°F WB | |
| | Outdoor: 47°F DB/43°F WB | |
| 2. Rated Heating Conditions: | Indoor: 70°F DB/60°F WB | |
| | Outdoor: 17°F DB/15°F WB | |
| 3. Heating Conditions, Compressor | Indoor: 70°F DB/60°F WB | |
| Operating at Max. Frequency | Outdoor: 5°F DB/5°F WB | |
| | | |


Model Number: A6MO21-48N2-M1

| Approval: _ | |
|-------------|----|
| Date: | |
| Constructio | n: |
| Unit #: | |
| Drawing #: | |

| OUTDOOR SPECIFICATION | | |
|------------------------------|------|--------------------------|
| Compressor Type | | ROTARY |
| Refrigerant | | R454B |
| Factory Charge | | 1400ml |
| Refrigerant Oil | | VG74 |
| Outdoor Air Flow (Max) (CFM) | | 4503 |
| Outdoor Noise Level (dBA) | | 63.0 |
| Dimension (W×D×H) | inch | 37-1/2 x 16-3/8 x 52-1/2 |
| | mm | 952 x 415 x 1333 |
| Package (W×D×H) | inch | 43-1/8 x 19-1/2 x 58-1/4 |
| | mm | 1095 x 495 x 1480 |
| Net/Gross Weight | lbs | 222/254 |
| | kg | 100.7/115.3 |

| ELECTRICAL | | |
|----------------------------------|--|--|
| Power Supply | 208/230V,60Hz,1Ph | |
| System MCA | 34 | |
| Connection Wiring | AWG 14-4 | |
| System MOCP | 40 | |
| Compressor RLA | 24 | |
| Outdoor Fan Motor RLA | 2.5 | |
| Outdoor Fan Motor W | 85 | |
| Indoor Fan Motor RLA | / | |
| Indoor Fan Motor W | / | |
| System Power Input @ Cooling (W) | 3740/(800 ~ 6000) | |
| System Power Input @ Heating (W) | 3532/(800 ~5200) | |
| MCA: Min. circuit amps (A) | MOCP: Max. over current protection (A) | |
| RLA: Rated load amps (A) | W: Fan motor rated output (W) | |

| PIPING | | |
|--|--|--|
| Liquid Size | 6x1/4in (6x6.35mm) | |
| Gas Size | 4x3/8in+2x1/2in (4x9.52mm+2x12.7mm) | |
| Drain Size | 5/8in (15.88mm) | |
| Max. Piping Length for all rooms | 262.4ft (80m) | |
| Max. Piping Length for one IDU | 114.8ft (35m) | |
| Max. Height Difference of IDU and ODU | 49.2ft (15m) | |
| Refrigerant Pre-charged Amount | 148.15oz (4200g) | |
| Refrigearant Precharge Length | 24.6ft (7.5m)x6 | |
| Additional Charge of Refrigerant (Φ6.35 (1/4") liquid pipe) | 0.16oz/ft (15g/m) | |
| Additional Charge of Refrigerant (Φ9.52 (3/8") liquid pipe) | 0.32oz/ft (30g/m) | |
| Connection Method | Flared | |



Installation Instruction

